LISTING SERVICE

LISTING No.   7300-0028:215   Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Notifier, One Fire-Lite Place, Northford CT 06472-1653
         Contact: Lawrence Flood (203) 484-1200

DESIGN: Model RFX wireless radio frequency (RF) interface system. Unit consists of models RFX, -R, -RI, wireless interface system, RFX-DP, Dress Panel with Models RFX-BX, -R enclosures. The unit allows communications between an intelligent addressable fire alarm control panel and up to 80 wireless smoke detectors. The RFX-R monitors the status of each wireless detector and forwards the information to the RFX interface board. The RFX forwards the information to the control panel through the panel's Signaling Line Circuit (SLC). The RFX-RI remote interface board allows up to four RFX-R wireless receivers to be utilized. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as radio frequency wireless interface system for use with separately listed compatible fire alarm control units.

11-14-2001

Date Issued: **MAY 8, 2002**   *Listing Expires **June 30, 2003***

A*uthorized By:*   **DIANE K. AREND**, *Senior Deputy*
         Program Manager